

MIDEA

Central Air Conditioning Heat Pump (HP)

Singlezone Non-Ducted, Wall Placement

AHRI Cert #*: 215333804


Outdoor Unit Model #*: D5CVRAH12AAJ

Indoor Model #*: D5FVHAH12XCJ

🔥 Maximum Heating Capacity (Btu/h) @5°F: 7,000

🔥 Rated Heating Capacity (Btu/h) @47°F*: 12,000

❄️ Rated Cooling Capacity (Btu/h) @95°F*: 12,000



Information Tables

Brand	MIDEA
Series	
Ducting Configuration	Singlezone Non-Ducted, Wall Placement
AHRI Certificate #*	215333804
Outdoor Unit Model #*	D5CVRAH12AAJ
Indoor Model #*	D5FVHAH12XCJ
Indoor Unit Type*	Mini-Splits
Furnace Model* #	
EER*	
SEER*	
HSPF (Region IV)*	
EER2+	8.8
SEER2+	19
HSPF2 (Region IV)*	9.2
HSPF2 (Region V)	7
ENERGY STAR V6.1	✗
ENERGY STAR V6.1 Cold Climate	✗
ENERGY STAR V5.0	✗
Federal Tax Credit Eligibility North	
Federal Tax Credit Eligibility South	
CEE Tier 1 Path A (2025)	✗
CEE Tier 1 Path B (2025)	✗
Capacity Maintenance (Rated 17°F/Rated 47°F)	64%
Capacity Maintenance (Rated 5°F/Rated 47°F)	58%
Capacity Maintenance (Max 5°F/Rated 47°F)	58%
Variable Capacity	✓
Integration	
Connectivity	
Operational Diagnostics	
Refrigerant	R-454B
Created At	2026-03-31
Updated At	2026-08-24
Sold In*	USA, Canada

Performance Specs

Heating / Cooling	Outdoor Dry Bulb	Indoor Dry Bulb	Unit	Min	Rated*	Max
Cooling	95°F	80°F	Btu/h*	3,600	12,000	12,500
			kW	0.31	1.36	1.4
			COP	3.4	2.59	2.62
Cooling	82°F	80°F	Btu/h*	3,900	-	12,000
			kW	0.17	-	0.62
			COP	6.72	-	5.67
Heating	47°F	70°F	Btu/h*	3,800	12,000	12,400
			kW	0.27	1.24	1.26
			COP	4.12	2.84	2.88
Heating	17°F	70°F	Btu/h*	2,500	7,700	7,900
			kW	0.49	0.87	0.96
			COP	1.5	2.59	2.41
Heating	5°F	70°F	Btu/h*	2,200	7,000	7,000
			kW	0.47	0.93	0.93
			COP	1.37	2.21	2.21