

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Certificate No.
0843-CPR-1221

Issue date
22-03-2023

Issue No.
3

Re-Issue date
27-11-2024



4705

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer:
Polyseam Ltd

Address:
15 St. Andrews Road, Huddersfield, West Yorkshire, HD1 6SB,
UK

Product:
Protecta FR Board / FR Flexi Board

Places of production:
Polyseam Ltd, 15. St. Andrews Road, Huddersfield, West
Yorkshire, HD1 6SB, UK

Harmonized requirements
EAD 350454-00-1104 & EAD 350141-00-1106

Scope of Certificate
0843-UKTA-22/0025, issued 26/11/2024 &
0843-UKTA-22/0034, issued 25/10/2024

On behalf of the Head of Approved Body:

A handwritten signature in blue ink, appearing to read 'Chris Johnson'.

Chris Johnson
Issued by UL International (UK) Ltd, Approved Body 0843.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in UKTA 22/0025 & UKTA 22/0034 of the above referenced standards, under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the EAD, in UKTA 22/0025 & UKTA 22/0034, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.



Detailed information sheet:

Product Reference:	Protecta FR Board / FR Flexi Board
Type:	Firestop – Coated board used as a penetration seal and linear joint seal
Description:	A coated mineral wool board used to reinstate the fire resistance performance of wall and floor constructions where they have been provided with apertures for the penetration of single or multiple services. The coated board can also be used to form linear gap seals where gaps are present. The intended use of Protecta FR Board / FR Flexi-Board is to reinstate the fire resistance performance of floor to floor/ floor to wall joints and wall gaps. Typical locations of linear joints include floors, the perimeter of floors, walls, ceilings and roofs. Protecta FR Board / FR Flexi-Board is supplied coated on one face, referenced 1-S, or on both faces, referenced 2-S. The board or boards are then cut to allow the penetration of the required services, before being inserted into the aperture in the wall or floor or cut to suit the linear gap dimensions.
Key Performance parameters:	0843-UKTA-22/0025 & 0843-UKTA-22/0034
Accessories:	- Protecta FR Pipe Wrap, a pipe closure device used to form penetration seals. - Protecta FR Graphite, sealant and pipe closure device used as a penetration seal. - Protecta FR Coating, coating for stone, mineral wool board used as a linear joint seal. - Protecta FR Acrylic, sealant used as a penetration seal and linear joint seal. - Protecta FR Collars, pipe closure device used as a penetration seal. - Protecta FR Service Coat FR1, acrylic based intumescent coating for cables, cable trays and metal pipes. - Protecta FR Adhesive, adhesive
Identification and intended use	label



Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier's installation instructions, technical datasheet and UKTA.
Limitations	See Technical Data Sheet and the UKTA
UL Report:	4791282064.6

Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE



Solutions

Form-ULID-006104 V8.0