



4705



UKCA CERTIFICATE

APPROVED BODY NUMBER 0843

UK CERTIFICATE OF CONSTANCY OF PERFORMANCE CERTIFICATE No. 0843-CPR-1222

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer:	Polyseam Ltd
Address:	15 St. Andrews Road, Huddersfield, West Yorkshire, HD1 6SB, UK
Product Description:	Firestop – Penetration Seals
Model Reference:	Protecta FR Collar
Places of production:	Polyseam Ltd, 15. St. Andrews Road, Huddersfield, West Yorkshire HD1 6SB, UK
UK Assessment Document(s) & UKTA:	0843-UKTA-22/0026 and EAD 350454-00-1104

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in 0843-UKTA-22/0026 and EAD 350454-00-1104 under system 1/1+ for the performance set out in the UKTA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 20th December 2022 and will remain valid as long as neither the UKTA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Date of 1st issue: 20th December 2022
Issue: 1
Date of re-issue: N/A
Issued by UL International (UK) Ltd., Approved Body 0843.

Signed: 
Name: Chris Johnson
Certification Decision Maker



4705



UKCA CERTIFICATE

Schedule for certificate No. 0843-CPR-1222

Detailed information sheet

Model Reference:	Protecta FR Collar
Type:	Firestop – Pipe closure device used as a penetration seal
Description:	A pipe closure device used to form penetration seals where combustible pipes, cables and metal pipes with insulation penetrate walls and floors. Protecta FR Collar is supplied with intumescent liner complete within metal steel shell, to be clamped around the service and screw fixed back to the supporting element. The Protecta FR Collar may be supplied with powder coated steel or stainless steel shell
Key Performance parameters:	See 0843-UKTA-22/0026

Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier's installation instructions.
---------------------------	---

Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

Date of 1st issue: 20th December 2022
Issue: 1
Date of re-issue: N/A
Issued by UL International (UK) Ltd., Approved Body 0843.

Signed: 
Name: Chris Johnson
Certification Decision Maker